



LIGHTNING IMPULSE WITHSTAND VOLTAGE	1470 kV	
POWER-FREQUENCY WITHSTAND VOLTAGE, WET	590 kV	
CRITICAL IMPULSE FLASHOVER, POSITIVE	1610 kV	
MAX. RIV AT 1000 kHz	1000 μV	
LOW-FREQUENCY TEST VOLTAGE (RIV)	210 kV	
CREEPAGE DISTANCE	- NOMINAL	272 in 6909 mm
	- MINIMUM	264 in 6705 mm
MINIMUM FAILING LOAD	- BENDING (UPRIGHT & UNDERHUNG)	900 lb 4 kN
	- TENSILE	25000 lb 111.2 kN
	- COMPRESSION	75000 lb 334 kN
	- TORSION	90000 in-lb 10.2 kNm
MAX. ANGULAR DEVIATION OF FIXING HOLES		1 °
TESTING ACC. TO ANSI C29.1		
MECHANICAL ROUTINE TEST: BENDING		4 x 50%
FIXING DEVICE MATERIAL: MALLEABLE CAST IRON, HOT DIP GALVANIZED		
APPROXIMATE WEIGHT	410 lb	186 kg



EGER PRODUCTS, INC.

REVISIONS:

PROPRIETARY AND CONFIDENTIAL
THE INFORMATION CONTAINED IN THIS
DRAWING IS THE SOLE PROPERTY OF
EGER PRODUCTS, INC.. ANY
REPRODUCTION IN PART OR AS A WHOLE
WITHOUT THE WRITTEN PERMISSION OF
EGER PRODUCTS INC. IS
PROHIBITED.

DATE: 8/1/2014

CUSTOMER:

SCALE: NTS

TR330

DRAWN BY: E. GREEN

DWG. OUTDOOR STATION POST INSULATOR

APPROVED BY:

MATERIAL: