



LIGHTNING IMPULSE WITHSTAND VOLTAGE	1470 kV
POWER-FREQUENCY WITHSTAND VOLTAGE, WET	590 kV
CRITICAL IMPULSE FLASHOVER, POSITIVE	1610 kV
MAX. RIV AT 1000 kHz	1000 μV
LOW-FREQUENCY TEST VOLTAGE (RIV)	210 kV
CREEPAGE DISTANCE	- NOMINAL 273 in 6934 mm
	- MINIMUM 264 in 6706 mm
MINIMUM FAILING LOAD	- BENDING (UPRIGHT & UNDERHUNG) 1750 lb 7.8 kN
	- TENSILE 40000 lb 178 kN
	- COMPRESSION 100000 lb 445 kN
	- TORSION 120000 in-lb 13.6 kNm
MAX. ANGULAR DEVIATION OF FIXING HOLES	1°
TESTING ACC. TO ANSI C29.1	
MECHANICAL ROUTINE TEST: BENDING	4 x 50%
FIXING DEVICE MATERIAL: MALLEABLE CAST IRON, HOT DIP GALVANIZED	
APPROXIMATE WEIGHT	532 lb 241 kg



EGER PRODUCTS, INC.

REVISIONS:

**PROPRIETARY AND CONFIDENTIAL**  
THE INFORMATION CONTAINED IN THIS  
DRAWING IS THE SOLE PROPERTY OF  
EGER PRODUCTS, INC. ANY  
REPRODUCTION IN PART OR AS A WHOLE  
WITHOUT THE WRITTEN PERMISSION OF  
EGER PRODUCTS INC. IS  
PROHIBITED.

DATE: 8/1/2014

CUSTOMER:

SCALE: NTS

TR372

DRAWN BY: E. GREEN

DWG. OUTDOOR STATION POST INSULATOR

APPROVED BY:

MATERIAL: